



LOW VOLTAGE FIRE/INTRUSION ALARM CHECKLIST

*This checklist is designed to be generic in content and may not include all requirements for your particular installation.
 Manufacturer's installation instructions must be adhered to and available to the inspector at the time of the inspection.*

REFERENCE		COMPLIANCE	
		YES	NO
WAC 296-150M	Alteration permit purchased and insignia issued.	<input type="checkbox"/>	<input type="checkbox"/>
RCW 18.27.200	Contractor doing work is registered.	<input type="checkbox"/>	<input type="checkbox"/>
HUD 3280.305	No holes bored in floor joist within 2" of top or bottom.	<input type="checkbox"/>	<input type="checkbox"/>
HUD 3280.307d	Exterior surfaces shall be sealed to resist the entrance of rodents.	<input type="checkbox"/>	<input type="checkbox"/>
HUD 3280.903	Protection from transportation shock and vibration.	<input type="checkbox"/>	<input type="checkbox"/>
NEC 110-36	All equipment shall be installed per specs.	<input type="checkbox"/>	<input type="checkbox"/>
NEC 725-6	Equipment to be bonded to frame. Bonding at frame to include a star washer.	<input type="checkbox"/>	<input type="checkbox"/>
NEC 725-7	All installations shall be in a workmanship-like manner.	<input type="checkbox"/>	<input type="checkbox"/>
NEC 725-8-6	Conductors shall be protected from physical damage.	<input type="checkbox"/>	<input type="checkbox"/>
NEC 725-41	Installation for a Class 2 circuit.	<input type="checkbox"/>	<input type="checkbox"/>
NEC 725-51	Circuit breaker for the transformer to be sized per manufacturer's instructions.	<input type="checkbox"/>	<input type="checkbox"/>
WAC 296-150M	Re-inspection fee charged if applicable.	<input type="checkbox"/>	<input type="checkbox"/>

Comments: _____

NOTE: UNLESS OTHERWISE SPECIFIED IN CODE, THE MANUFACTURER'S INSTALLATION INSTRUCTIONS MUST BE FOLLOWED.